

## Attachment L - Results Summary Lead in Water Samples

School Name: Triangle Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
TES-1-MO-TF	TES-30-1118-01	Sink faucet; Main Office work room	98.6	Yes
TES-1-MO-TF1	TES-30-1118-02	Sink faucet; Main Office main area	3.13	No
TES-1-NURSE-NS	TES-30-1118-03	Sink faucet; Nurse Office	ND	No
TES-1-CONFERENCE-SB	TES-30-1118-04	Bubbler on sink; Conf. Room/Guidance	4.51	No
TES-1-CONFERENCE-TF	TES-30-1118-05	Sink faucet; Conf. Room/Guidance	1.64	No
TES-1-110-SB	TES-30-1118-06	Bubbler on sink; Room 110	ND	No
TES-1-110-CF	TES-30-1118-07	Sink faucet; Room 110	1.45	No
TES-1-109-SB	TES-30-1118-08	Bubbler on sink; Room 109	1.19	No
TES-1-109-CF	TES-30-1118-09	Sink faucet; Room 109	2.72	No
TES-1-108-SB	TES-30-1118-10	Bubbler on sink; Room 108	ND	No
TES-1-108-CF	TES-30-1118-11	Sink faucet; Room 108	1.96	No
TES-1-102-SB	TES-30-1118-12	Bubbler on sink; Room 102	ND	No
TES-1-102-CF	TES-30-1118-13	Sink faucet; Room 102	1.39	No
TES-1-103-SB	TES-30-1118-14	Bubbler on sink; Room 103	3.05	No
TES-1-103-CF	TES-30-1118-15	Sink faucet; Room 103	2.29	No
TES-1-107-SB	TES-30-1118-16	Bubbler on sink; Room 107	ND	No
TES-1-107-CF	TES-30-1118-17	Sink faucet; Room 107	1.63	No
TES-1-104-SB	TES-30-1118-18	Bubbler on sink; Room 104	ND	No
TES-1-104-CF	TES-30-1118-19	Sink faucet; Room 104	1.57	No
TES-1-106-SB	TES-30-1118-20	Bubbler on sink; Room 106	1.38	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: Triangle Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
TES-1-106-CF	TES-30-1118-21	Sink faucet; Room 106	3.07	No
TES-1-105-CF	TES-30-1118-22	Sink faucet; Room 105	1.19	No
TES-1-LIBRARY-CF	TES-30-1118-23	Sink faucet; Library office work room	4.92	No
TES-1-111-SB	TES-30-1118-24	Bubbler on sink; Room 111	1.36	No
TES-1-111-CF	TES-30-1118-25	Sink faucet; Room 111	2.14	No
TES-1-OT/PT-CF	TES-30-1118-26	Sink faucet; OT/PT Room	7.29	No
TES-1-112-SB	TES-30-1118-27	Bubbler on sink; Room 112	1.55	No
TES-1-112-CF	TES-30-1118-28	Sink faucet; Room 112	8.97	No
TES-1-120-SB	TES-30-1118-29	Bubbler on sink; Room 120	ND	No
TES-1-120-CF	TES-30-1118-30	Sink faucet; Room 120	1.97	No
TES-1-119-SB	TES-30-1118-31	Bubbler on sink; Room 119	1.41	No
TES-1-119-CF	TES-30-1118-32	Sink faucet; Room 119	3.80	No
TES-1-113-SB	TES-30-1118-33	Bubbler on sink; Room 113	ND	No
TES-1-113-CF	TES-30-1118-34	Sink faucet; Room 113	2.62	No
TES-1-118-SB	TES-30-1118-35	Bubbler on sink; Room 118	1.07	No
TES-1-118-CF	TES-30-1118-36	Sink faucet; Room 118	2.86	No
TES-1-114-SB	TES-30-1118-37	Bubbler on sink; Room 114	1.13	No
TES-1-114-CF	TES-30-1118-38	Sink faucet; Room 114	3.96	No
TES-1-117-SB	TES-30-1118-39	Bubbler on sink; Room 117	ND	No
TES-1-117-CF	TES-30-1118-40	Sink faucet; Room 117	1.97	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Samples

School Name: Triangle Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
TES-1-115-SB	TES-30-1118-41	Bubbler on sink; Room 115	2.09	No
TES-1-115-CF	TES-30-1118-42	Sink faucet; Room 115	3.10	No
TES-1-116-SB	TES-30-1118-43	Bubbler on sink; Room 116	2.23	No
TES-1-116-CF	TES-30-1118-44	Sink faucet; Room 116	2.84	No
TES-1-MOD1-CF	TES-30-1118-45	Sink faucet; MOD 1 CST	5.6	No
TES-1-MOD2-SB	TES-30-1118-46	Bubbler on sink; MOD 2 REACH	8.13	No
TES-1-MOD2-CF	TES-30-1118-47	Sink faucet; MOD2 REACH	2.19	No
TES-1-KITCHEN-FP	TES-30-1118-48	Sink faucet; Kitchen, Food Prep	4.12	No
TES-1-FACULTY-TF	TES-30-1118-49	Sink faucet; Room FACULTY	ND	No
TES-1-FACULTY-IM	TES-30-1118-50	Sink faucet; Room FACULTY	ND	No
TES-1-125-SB	TES-30-1118-51	Bubbler on sink; Room 125	1.05	No
TES-1-125-CF	TES-30-1118-52	Sink faucet; Room 125	22.4	Yes
TES-1-121-SB	TES-30-1118-53	Bubbler on sink; Room 121	1.41	No
TES-1-121-CF	TES-30-1118-54	Sink faucet; Room 121	5.53	No
TES-1-122-SB	TES-30-1118-55	Bubbler on sink; Room 122	ND	No
TES-1-122-CF	TES-30-1118-56	Sink faucet; Room 122	3.00	No
TES-1-123-SB	TES-30-1118-57	Bubbler on sink; Room 123	ND	No
TES-1-123-CF	TES-30-1118-58	Sink faucet; Room 123	2.88	No
QC BLANK	TES-30-1118-59	DI Blank	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported