



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

1/4/2018

Phone: (856) 616-9516
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2017. The results are tabulated on the attached data pages for the following client designated project:

HTPS - Sunnymead Elementary School - PR-171031-1172

The reference number for these samples is EMSL Order #011710041. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011710041
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/20/17 10:45 AM

Project: **HTPS - Sunnymead Elementary School - PR-171031-1172**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>					
SES-13-1220-01 SES-1-10-SB; Bubbler on Sink; Room 10		12/20/2017	011710041-0001					
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	189	5.00	µg/L	12/28/2017	TD	12/28/2017	SM
SES-13-1220-02 SES-1-12-SB; Bubbler on Sink; Room 12		12/20/2017	011710041-0002					
200.8	Lead	45.7	1.00	µg/L	12/28/2017	TD	12/28/2017	SM
SES-13-1220-03 SES-1-13-SB; Bubbler on Sink; Room 13		12/20/2017	011710041-0003					
200.8	Lead	229	5.00	µg/L	12/21/2017	SM	12/21/2017	SM
SES-13-1220-04 SES-1-16-SB; Bubbler on Sink; Room 16		12/20/2017	011710041-0004					
200.8	Lead	3.99	1.00	µg/L	12/21/2017	SM	12/21/2017	SM
SES-13-1220-05 SES-HCAF-DW; Water Fountain in Hall by Cafeteria		12/20/2017	011710041-0005					
200.8	Lead	1.49	1.00	µg/L	12/21/2017	SM	12/21/2017	SM
SES-13-1220-06 SES-1-7-SB; Bubbler on Sink; Room 7		12/20/2017	011710041-0006					
200.8	Lead	4.37	1.00	µg/L	12/21/2017	SM	12/21/2017	SM
SES-13-1220-07 SES-1-5-SB; Bubbler on Sink; Room 5		12/20/2017	011710041-0007					
200.8	Lead	108	2.00	µg/L	12/21/2017	SM	12/21/2017	SM
SES-13-1220-08 SES-1-6-SB; Bubbler on Sink; Room 6		12/20/2017	011710041-0008					
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011710041

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 12/20/17 10:45 AM

Project: HTPS - Sunnymeade Elementary School - PR-171031-1172

Analytical Results

Client Sample Description SES-13-1220-08
 SES-1-6-SB; Bubbler on Sink; Room 6
Collected: 12/20/2017
Lab ID: 011710041-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.1	1.00	µg/L	12/28/2017	TD	12/28/2017	SM

Client Sample Description SES-13-1220-09
 QC Blank
Collected: 12/20/2017
Lab ID: 011710041-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/21/2017	SM	12/21/2017	SM

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)