

HMS-1-D26-CF-P	N	2224926080	ALS	NJ PA010	4/22/2017	9:55	EPA 200.8	5/4/2017	12:50	3.8	2	1	Y	
HMS-1-D27-SB-P	N	2224926081	ALS	NJ PA010	4/22/2017	9:53	EPA 200.8	5/4/2017	12:53	< 2.0	2	1	Y	ND
HMS-1-D27-CF-P	N	2224926082	ALS	NJ PA010	4/22/2017	9:54	EPA 200.8	5/4/2017	12:55	< 2.0	2	1	Y	ND
HMS-1-D28-SB-P	N	2224926083	ALS	NJ PA010	4/22/2017	9:52	EPA 200.8	5/4/2017	12:58	< 2.0	2	1	Y	ND
HMS-1-D28-CF-P	N	2224926084	ALS	NJ PA010	4/22/2017	9:53	EPA 200.8	5/4/2017	13:01	2.1	2	1	Y	
HMS-1-D29-SB-P	N	2224926085	ALS	NJ PA010	4/22/2017	9:50	EPA 200.8	5/4/2017	13:04	< 2.0	2	1	Y	ND
HMS-1-D29-CF-P	N	2224926086	ALS	NJ PA010	4/22/2017	9:51	EPA 200.8	5/4/2017	13:17	5.8	2	1	Y	
HMS-1-D30-SB-P	N	2224926087	ALS	NJ PA010	4/22/2017	9:48	EPA 200.8	5/4/2017	13:20	< 2.0	2	1	Y	ND
HMS-1-D30-CF-P	N	2224926088	ALS	NJ PA010	4/22/2017	9:49	EPA 200.8	5/4/2017	13:23	3.1	2	1	Y	
HMS-1-D7-SB-P	N	2224926089	ALS	NJ PA010	4/22/2017	9:28	EPA 200.8	5/4/2017	13:25	< 2.0	2	1	Y	ND
HMS-1-D7-CF-P	N	2224926090	ALS	NJ PA010	4/22/2017	9:29	EPA 200.8	5/4/2017	13:28	2.9	2	1	Y	

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type - (P)primary / (F)lush / Number in Sequence

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT = Kettle
- SS = Slop Sink
- TF = Teachers Faucet
- WC = Water Cooler