

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sampled	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y/N	Qualifier
Field Blank	N	2228698001	ALS	NJ PA010	5/1/2017	0:00	EPA 200.8	5/12/2017	14:48	< 2.0	2	1	Y	ND
TES-1-MO-TF1-P2	N	2228698002	ALS	NJ PA010	5/1/2017	6:22	EPA 200.8	5/12/2017	14:51	52.6	2	1	Y	Y
TES-1-MO-TF1-F	N	2228698003	ALS	NJ PA010	5/1/2017	6:23	EPA 200.8	5/12/2017	14:59	< 2.0	2	1	Y	ND
TES-1-MO-TF2-P2	N	2228698004	ALS	NJ PA010	5/1/2017	6:28	EPA 200.8	5/12/2017	15:02	9.9	2	1	Y	Y
TES-1-MO-TF2-F	N	2228698005	ALS	NJ PA010	5/1/2017	6:29	EPA 200.8	5/12/2017	15:05	< 2.0	2	1	Y	ND
Exceeds EPA Action Limit (> 15.5ppb)														
Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush														
OUTLET TYPE														
BF = Bathroom Faucet														
CF = Classroom Faucet														
DW = Drinking Water Fountain														
FP = Food Prep														
HS = Hand Sink														
IM = Ice Machine														
KC = Kitchen Outlet, Cold														
KT= Kettle														
SS = Slop Sink														
TF = Teachers Faucet														
WC = Water Cooler														

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sampled	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y/N	Qualifier
Field Blank	N	2231530001	ALS	NJ PA010	5/17/2017	6:25	EPA 200.8	5/23/2017	18:52	< 2.0	2	1	Y	ND
TES-1-125-CF-N	N	2231530002	ALS	NJ PA010	5/17/2017	6:27	EPA 200.8	5/23/2017	18:58	< 2.0	2	1	Y	ND
TES-1-125-SB-N	N	2231530003	ALS	NJ PA010	5/17/2017	6:26	EPA 200.8	5/23/2017	18:55	3.2	2	1	Y	
Exceeds EPA Action Limit (> 15ppb)														
Bldg ID - Room / Location ID / Floor - Outlet Type - (P)rimary / (F)lush / Number in Sequence														
OUTLET TYPE														
BF = Bathroom Faucet														
CF = Classroom Faucet														
DW = Drinking Water Fountain														
FP = Food Prep														
HS = Hand Sink														
IM = Ice Machine														
KC = Kitchen Outlet, Cold														
KT= Kettle														
SS = Slop Sink														
TF = Teachers Faucet														
WC = Water Cooler														