

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sampled	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y/N	Qualifier
FIELD BLANK	N	2228705001	ALS	NJ PA010	5/5/2017	7:28	EPA 200.8	5/17/2017	18:51	< 2.0		2	1 Y	ND
WES-1-120-SB-P2	N	2228705002	ALS	NJ PA010	5/5/2017	7:30	EPA 200.8	5/17/2017	18:54	21.2		2	1 Y	
WES-1-120-SB-F	N	2228705003	ALS	NJ PA010	5/5/2017	7:31	EPA 200.8	5/17/2017	19:02	34.8		2	1 Y	
WES-1-119-SB-P2	N	2228705004	ALS	NJ PA010	5/5/2017	7:35	EPA 200.8	5/17/2017	19:10	6.6		2	1 Y	
WES-1-119-SB-F	N	2228705005	ALS	NJ PA010	5/5/2017	7:36	EPA 200.8	5/17/2017	19:13	3		2	1 Y	
WES-1-113-SB-P2	N	2228705006	ALS	NJ PA010	5/5/2017	7:38	EPA 200.8	5/17/2017	19:15	24.7		2	1 Y	
WES-1-113-SB-F	N	2228705007	ALS	NJ PA010	5/5/2017	7:39	EPA 200.8	5/17/2017	19:18	3.1		2	1 Y	
WES-1-115-SB-P2	N	2228705008	ALS	NJ PA010	5/5/2017	7:42	EPA 200.8	5/17/2017	19:21	32.9		2	1 Y	
WES-1-115-SB-F	N	2228705009	ALS	NJ PA010	5/5/2017	7:44	EPA 200.8	5/17/2017	19:24	2.2		2	1 Y	
WES-1-116-SB-P2	N	2228705010	ALS	NJ PA010	5/5/2017	7:50	EPA 200.8	5/17/2017	19:26	10.4		2	1 Y	
WES-1-116-SB-F	N	2228705011	ALS	NJ PA010	5/5/2017	7:51	EPA 200.8	5/17/2017	19:34	3.7		2	1 Y	

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type - (P)primary / (F)lush / Number in Sequence

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Outlet, Cold

KT= Kettle

SS = Slop Sink

TF = Teachers Faucet

WC = Water Cooler