

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sampled	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y/N	Qualifier
FIELD BLANK	N	2226234001	ALS	NJ PA010	4/25/2017	7:08	EPA 200.8	5/5/2017	15:10	< 2.0	2	1	Y	ND
WRES-1-NURSE-NS2-P2	N	2226234002	ALS	NJ PA010	4/25/2017	7:09	EPA 200.8	5/5/2017	15:12	10.6	2	1	Y	
WRES-1-NURSE-NS2-F	N	2226234003	ALS	NJ PA010	4/25/2017	7:10	EPA 200.8	5/5/2017	15:15	< 2.0	2	1	Y	ND
WRES-1-114-CF-P2	N	2226234004	ALS	NJ PA010	4/25/2017	7:12	EPA 200.8	5/5/2017	15:18	190	2	1	Y	
WRES-1-114-CF-F	N	2226234005	ALS	NJ PA010	4/25/2017	7:13	EPA 200.8	5/5/2017	15:20	< 2.0	2	1	Y	ND

Exceeds EPA Action Limit (> 15ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type - (P)rimary / (F)lush / Number in Sequence

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SS = Slop Sink
- TF = Teachers Faucet
- WC = Water Cooler